

## Technical Information Smoke detector testspray



presto smoke detector test spray is an effective test spray with the optical and photoelectric smoke detector reliably and quickly can be tested without additional test equipment.

### Fields of application:

Households, industry, trade, public buildings

## Quality and properties

- Oil-free
- Leaves no residues
- Sprays a fine mist
- For optical and photoelectric smoke detectors
- Easy and fast test method without additional test equipment

## Physical and chemical data

- **Basis:** alcohol, hydrocarbons, iso-paraffin
- **Colour:** transparent
- **Smell:** alcoholic
- **VOC content:** 95%
- **Solid:** 0%
- **Relative density at 20°C:** 0,59 - 0,61 g/ml
- **Vapour pressure at 20°C:** 4.2 bar
- **Storage stability:**  
10 years if appropriate storage provided (=10°-25°C, relative air humidity of max. 60%)
- **Size:**  
aerosol can, maximum nominal volume 150 ml

## Environment and labelling

**Environmentally sound:** European Aerosols is committed to apply formulations without restricted or critical ingredients and to achieve best possible performance. The caps and packagings are made of recyclable material.

**Disposal:** Only the completely emptied cans should be put into the recycling skip or appropriate container for reclaimable refuse. Cans which are not empty should be disposed off as "special refuse".

**Marking/Labelling:** All products made by European Aerosols comply with the actual labelling regulations according to Preparation Guideline 1999/45/EG. All aerosols correspond to TRGS 200 and TRG 300 as well as to aerosol guideline 75/324/EWG in the actually valid version.

## Using instructions

**Before use, carefully read and observe the warning texts on the label!**

### Application:

- Bring can to room temperature.
- Operating temperature 15 to 35°C.
- Shake can before use.
- Keep the Test spray straight up and at a distance of 25 to 30 cm for a few seconds (5 seconds) spray in the direction of the smoke detector.
- The reaction starts at a properly functioning detector within a few seconds.
- If there is no response, repeat the test.
- If despite repeated examination no reaction, so please check the battery first.
- After continued lack of reaction, the defective smoke detector must be replaced.

## Order informations

## Disclaimer of liability

This application-technological information is given to the best of our knowledge. The notes mentioned herein are, however, non-binding and do not exempt you from own tests to see whether the products supplied by us are suitable for your special application. The use and processing is beyond our control and therefore exclusively in the responsibility of the user. European Aerosols is let off the liability, unless the liability-based incident is caused by a fault incurred to European Aerosols.

As of: November 7, 2014

This release replaces all eventually earlier issued versions.

Print date: 02.05.2024

European Aerosols | Wolfraamweg 2 | 8471 XC Wolvega | NL | [info-nl@european-aerosols.com](mailto:info-nl@european-aerosols.com)